



### **1. Kalibriergegenstand / Calibration object**

8 Channel Data Acquisition DEWETRON TRION-2402-dSTG, S/N: A01505F8

### **2. Kalibrierverfahren / Calibration procedure**

Die Kalibrierung erfolgt durch Vergleich der durch die Kalibrierstelle / Normale dargestellten Werte mit den Ausgangsgrößen am Kalibriergegenstand beziehungsweise den am Kalibriergegenstand angezeigten Werten.  
*The calibration is made by comparing the readings from the laboratory / standards to the output of the calibration object respectively the values displayed on the calibration object.*

Prüfroutine / *Calibration procedure*: TRION-240x-dSTG\_Akkred, Rev. 2.00

### **3. Messergebnisse / Measurement results**

Die Kalibrierung im Rahmen der Akkreditierung umfasst die Messgrößen Gleichspannung, Wechselspannung, Gleichstrom, Wechselstrom und Gleichstromwiderstand.

Die Messergebnisse beziehen sich ausschließlich auf diesen Kalibriergegenstand zum Zeitpunkt der Kalibrierung.  
*The calibration scope of the accreditation contains the quantities direct voltage, alternating voltage, direct current, alternating current and direct current resistance.*

*The measurement results are exclusively linked to this calibration object at the time of calibration.*

### **4. Messunsicherheit / Measurement uncertainty**

Angegeben ist die erweiterte Messunsicherheit, die sich aus der Standardmessunsicherheit durch Multiplikation mit dem Erweiterungsfaktor  $k=2$  ergibt. Sie wurde gemäß EA-4/02 ermittelt. Der Wert der Messgröße liegt im Regelfall mit einer Wahrscheinlichkeit von annähernd 95% im zugeordneten Werteintervall.

Ein Anteil für die Langzeitstabilität des Kalibriergegenstandes ist nicht enthalten.

*The stated extended measurement uncertainty is derived from the standard uncertainty of measurement multiplied by the coverage factor  $k=2$ . It has been determined according to EA-4/02. The measured quantity is inside the corresponding value interval with a probability of approximately 95%.*

*A factor for the long time stability of the calibration object is not taken into account.*

### **5. Umgebungsbedingungen / environmental conditions**

Temperatur / *Temperature*: 23,4 °C

Rel. Luftfeuchte / *Rel. humidity*: 36,8 % r.H.

Kalibrierort / *Place of calibration*: DEWETRON GmbH, Parkring 4, 8074 Grambach, Austria

### **6. Auftragsnummer / Reference Number**

### **7. Status / Status**

PASS ()

AS-FOUND: Eingangskalibration / *Incoming calibration*

AS-LEFT: Ausgangskalibration / *Outgoing calibration*

FOUND/LEFT: Eingangskalibration erfüllt Herstellerspezifikation / *Incoming calibration according to manufacturer specifications*

PASS: Messergebnis liegt innerhalb der Herstellerspezifikationen (ohne Berücksichtigung der Messunsicherheiten) / *Measurement result is within manufacturer's specifications (without taking into account the measurement uncertainties)*

FAIL: Das Messergebnis liegt nicht innerhalb der Herstellerspezifikationen (ohne Berücksichtigung der Messunsicherheiten) / *Measurement result is out of manufacturer's specifications (without taking into account the measurement uncertainties)*

### **8. Verwendete Fußnoten / Used foot notes:**

(1) Zusätzliche Messwerte außerhalb des akkreditierten Bereiches, es kann keine Konformitätsaussage getroffen werden.

*(1) Additional measured values outside the accredited scope, a conformity statement cannot be made.*

### **9. Kommentare / Comments**

test

Für die Festlegung und Einhaltung einer angemessenen Frist zur Wiederholung der Kalibrierung ist der Benutzer verantwortlich.

*The user is responsible for the definition and the compliance to a reasonable period for repeating the calibration.*



**DEWETRON GmbH**  
Parking 4  
8074 Grambach  
AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
*Calibration Certificate according to ISO/IEC 17025*

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**10. Verwendete Normale / Standards used**

<u>Asset</u>	<u>Description</u>	<u>Serial Number</u>	<u>Certificate No.</u>	<u>Cal Date</u>	<u>Due Date</u>
5522A 02	5522A CALIBRATOR	6032901	SA01377628	3-Mär-2025	3-Mär-2026
Agilent 3458A	3458A Multimeter	MY45043170	01102024	1-Okt-2024	1-Okt-2025



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Current Temperature of DMM and Calibrator								
DMM:	42.9°C							
Calibrator:	26.57°C							
Kalibrierverfahren / calibration method:								
CAL-KV-01_Gleichspannung_v1.0_2024-07-04.xlsx-02								
CAL-KV-01_Gleichspannung_v1.0_2024-07-04.xlsx-05								
CAL-KV-02_Wechselspannung_v1.0_2024-07-04.xlsx-02C								
CAL-KV-02_Wechselspannung_v1.0_2024-07-04.xlsx-04C								
CAL-KV-03_Gleichstromstärke_v1.0_2024-07-04.xlsx-07								
API Version: 7.4.2.7598								
Card Type: TRION-2402-dSTG-8-RJ								
Firmware Version: 1120								
Model version: 1.03								
XML version: SVN 1507299269								
SN. of board: A01505F8								
SN. of connector: 00466668								
Excitation Voltage Calibration								
Accuracy: 0.03% of Value ±1mV								
Channel 1	0.5000 V	0.499293 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000707 V	61.5%	Pass
Channel 1	1.0000 V	1.000110 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000110 V	8.47%	Pass
Channel 1	2.0000 V	1.999407 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000593 V	37.1%	Pass
Channel 1	5.0000 V	5.000594 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000594 V	23.7%	Pass
Channel 1	10.0000 V	9.999909 V	9.996000 V	10.004000 V	87.00 e-06 V	-0,000091 V	2.27%	Pass
Channel 1	12.0000 V	12.000182 V	11.995400 V	12.004600 V	170.00 e-06 V	0,000182 V	3.95%	Pass
Channel 2	0.5000 V	0.499681 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000319 V	27.7%	Pass
Channel 2	1.0000 V	1.000195 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000195 V	15%	Pass
Channel 2	2.0000 V	1.999372 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000628 V	39.2%	Pass
Channel 2	5.0000 V	5.000089 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000089 V	3.55%	Pass
Channel 2	10.0000 V	9.999977 V	9.996000 V	10.004000 V	87.00 e-06 V	-0,000023 V	0.575%	Pass
Channel 2	12.0000 V	12.000329 V	11.995400 V	12.004600 V	170.00 e-06 V	0,000329 V	7.14%	Pass
Channel 3	0.5000 V	0.499438 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000562 V	48.9%	Pass
Channel 3	1.0000 V	1.000207 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000207 V	16%	Pass
Channel 3	2.0000 V	1.999485 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000515 V	32.2%	Pass
Channel 3	5.0000 V	5.000102 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000102 V	4.06%	Pass
Channel 3	10.0000 V	9.999923 V	9.996000 V	10.004000 V	87.00 e-06 V	-0,000077 V	1.93%	Pass
Channel 3	12.0000 V	11.999793 V	11.995400 V	12.004600 V	170.00 e-06 V	-0,000207 V	4.5%	Pass
Channel 4	0.5000 V	0.499246 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000754 V	65.5%	Pass
Channel 4	1.0000 V	1.000015 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000015 V	1.14%	Pass
Channel 4	2.0000 V	1.999565 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000435 V	27.2%	Pass
Channel 4	5.0000 V	5.000058 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000058 V	2.32%	Pass
Channel 4	10.0000 V	9.999979 V	9.996000 V	10.004000 V	87.00 e-06 V	-0,000021 V	0.533%	Pass
Channel 4	12.0000 V	11.999781 V	11.995400 V	12.004600 V	170.00 e-06 V	-0,000219 V	4.77%	Pass
Channel 5	0.5000 V	0.499481 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000519 V	45.1%	Pass
Channel 5	1.0000 V	1.000180 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000180 V	13.8%	Pass
Channel 5	2.0000 V	1.999165 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000835 V	52.2%	Pass
Channel 5	5.0000 V	5.000267 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000267 V	10.7%	Pass
Channel 5	10.0000 V	9.999908 V	9.996000 V	10.004000 V	87.00 e-06 V	-0,000092 V	2.29%	Pass
Channel 5	12.0000 V	12.000079 V	11.995400 V	12.004600 V	170.00 e-06 V	0,000079 V	1.72%	Pass
Channel 6	0.5000 V	0.499504 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000496 V	43.2%	Pass
Channel 6	1.0000 V	1.000193 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000193 V	14.9%	Pass
Channel 6	2.0000 V	1.999469 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000531 V	33.2%	Pass
Channel 6	5.0000 V	5.000239 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000239 V	9.55%	Pass
Channel 6	10.0000 V	9.999973 V	9.996000 V	10.004000 V	87.00 e-06 V	-0,000027 V	0.686%	Pass
Channel 6	12.0000 V	12.000264 V	11.995400 V	12.004600 V	170.00 e-06 V	0,000264 V	5.75%	Pass
Channel 7	0.5000 V	0.499311 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000689 V	59.9%	Pass
Channel 7	1.0000 V	1.000136 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000136 V	10.5%	Pass
Channel 7	2.0000 V	1.998996 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,001004 V	62.8%	Pass
Channel 7	5.0000 V	5.000822 V	4.997500 V	5.002500 V	46.00 e-06 V	0,000822 V	32.9%	Pass
Channel 7	10.0000 V	10.000059 V	9.996000 V	10.004000 V	87.00 e-06 V	0,000059 V	1.46%	Pass
Channel 7	12.0000 V	12.000188 V	11.995400 V	12.004600 V	170.00 e-06 V	0,000188 V	4.09%	Pass
Channel 8	0.5000 V	0.499298 V	0.498850 V	0.501150 V	6.90 e-06 V	-0,000702 V	61.1%	Pass
Channel 8	1.0000 V	1.000184 V	0.998700 V	1.001300 V	11.00 e-06 V	0,000184 V	14.2%	Pass
Channel 8	2.0000 V	1.999250 V	1.998400 V	2.001600 V	21.00 e-06 V	-0,000750 V	46.9%	Pass
Channel 8	5.0000 V	4.999958 V	4.997500 V	5.002500 V	46.00 e-06 V	-0,000042 V	1.68%	Pass
Channel 8	10.0000 V	10.000098 V	9.996000 V	10.004000 V	87.00 e-06 V	0,000098 V	2.44%	Pass
Channel 8	12.0000 V	12.000273 V	11.995400 V	12.004600 V	170.00 e-06 V	0,000273 V	5.94%	Pass

Excitation Current Calibration  
 Accuracy: 0.05% of Value ±2uA



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Channel 1	0.2000 mA	0.200288 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000288 mA	13.7%	Pass
Channel 1	1.0000 mA	1.000072 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	0,000072 mA	2.89%	Pass
Channel 1	5.0000 mA	4.999356 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	-0,000644 mA	14.3%	Pass
Channel 1	20.0000 mA	19.996238 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,003762 mA	31.3%	Pass
Channel 2	0.2000 mA	0.200050 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000050 mA	2.4%	Pass
Channel 2	1.0000 mA	1.000281 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	0,000281 mA	11.2%	Pass
Channel 2	5.0000 mA	4.999202 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	-0,000798 mA	17.7%	Pass
Channel 2	20.0000 mA	19.995613 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,004387 mA	36.6%	Pass
Channel 3	0.2000 mA	0.200309 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000309 mA	14.7%	Pass
Channel 3	1.0000 mA	0.999743 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	-0,000257 mA	10.3%	Pass
Channel 3	5.0000 mA	4.999852 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	-0,000148 mA	3.28%	Pass
Channel 3	20.0000 mA	19.996323 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,003677 mA	30.6%	Pass
Channel 4	0.2000 mA	0.200032 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000032 mA	1.5%	Pass
Channel 4	1.0000 mA	0.999889 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	-0,000111 mA	4.43%	Pass
Channel 4	5.0000 mA	5.000246 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	0,000246 mA	5.47%	Pass
Channel 4	20.0000 mA	19.995993 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,004007 mA	33.4%	Pass
Channel 5	0.2000 mA	0.200114 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000114 mA	5.44%	Pass
Channel 5	1.0000 mA	1.000139 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	0,000139 mA	5.54%	Pass
Channel 5	5.0000 mA	4.999273 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	-0,000727 mA	16.1%	Pass
Channel 5	20.0000 mA	19.996481 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,003519 mA	29.3%	Pass
Channel 6	0.2000 mA	0.200055 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000055 mA	2.61%	Pass
Channel 6	1.0000 mA	0.999943 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	-0,000057 mA	2.27%	Pass
Channel 6	5.0000 mA	4.999454 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	-0,000546 mA	12.1%	Pass
Channel 6	20.0000 mA	19.997094 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,002906 mA	24.2%	Pass
Channel 7	0.2000 mA	0.200371 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	0,000371 mA	17.7%	Pass
Channel 7	1.0000 mA	1.000228 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	0,000228 mA	9.1%	Pass
Channel 7	5.0000 mA	5.000275 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	0,000275 mA	6.11%	Pass
Channel 7	20.0000 mA	19.998238 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,001762 mA	14.7%	Pass
Channel 8	0.2000 mA	0.199718 mA	0.197900 mA	0.202100 mA	14.00 e-06 mA	-0,000282 mA	13.4%	Pass
Channel 8	1.0000 mA	0.999696 mA	0.997500 mA	1.002500 mA	42.00 e-06 mA	-0,000304 mA	12.2%	Pass
Channel 8	5.0000 mA	4.999346 mA	4.995500 mA	5.004500 mA	240.00 e-06 mA	-0,000654 mA	14.5%	Pass
Channel 8	20.0000 mA	19.996899 mA	19.988000 mA	20.012000 mA	1.80 e-03 mA	-0,003101 mA	25.8%	Pass

Performing Amplifier Zero Balance

Pass (1)

DC Accuracy:  
 0.02% of reading +/-0.02% of Range +/-20uV

AC Accuracy: (additional to DC tolerance, not specified by manufacturer)  
 DC to 1kHz : no additional tolerance  
 >1kHz to 5kHz : +/- 0.18% of reading  
 >5kHz to 10kHz : +/- 0.48% of reading  
 >10kHz to 20kHz : +/- 0.98% of reading

All Tests done with appropriate Range  
 SampleRate for Testsignals >1kHz: 200ks/s  
 SampleRate for all other Tests: 50ks/s

Range: 0.01V  
 #####

Test @ 0V DC

Channel 1	0.000000 V	0.000003 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000003 V	15.2%	Pass
Channel 2	0.000000 V	0.000002 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000002 V	10%	Pass
Channel 3	0.000000 V	0.000003 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000003 V	15.3%	Pass
Channel 4	0.000000 V	0.000002 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000002 V	11.1%	Pass
Channel 5	0.000000 V	0.000002 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000002 V	10.5%	Pass
Channel 6	0.000000 V	0.000002 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000002 V	9.01%	Pass
Channel 7	0.000000 V	0.000002 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000002 V	10.3%	Pass
Channel 8	0.000000 V	0.000002 V	-0.000022 V	0.000022 V	3.40 e-06 V	0,000002 V	7.9%	Pass

Test @ 0.001V DC

Channel 1	0.001000 V	0.001004 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000004 V	16.1%	Pass
Channel 2	0.001000 V	0.001002 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000002 V	9.2%	Pass
Channel 3	0.001000 V	0.001003 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000003 V	15.1%	Pass
Channel 4	0.001000 V	0.001003 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000003 V	11.9%	Pass
Channel 5	0.001000 V	0.001002 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000002 V	10.6%	Pass
Channel 6	0.001000 V	0.001002 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000002 V	8.12%	Pass
Channel 7	0.001000 V	0.001003 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000003 V	11.8%	Pass
Channel 8	0.001000 V	0.001002 V	0.000978 V	0.001022 V	3.40 e-06 V	0,000002 V	7.06%	Pass

Test @ 0.005V DC

Channel 1	0.005000 V	0.005004 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000004 V	16.7%	Pass
Channel 2	0.005000 V	0.005002 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000002 V	8.72%	Pass
Channel 3	0.005000 V	0.005004 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000004 V	16.1%	Pass
Channel 4	0.005000 V	0.005003 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000003 V	13%	Pass
Channel 5	0.005000 V	0.005003 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000003 V	11.1%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Channel 6	0.005000 V	0.005002 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000002 V	7.3%	Pass
Channel 7	0.005000 V	0.005003 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000003 V	14%	Pass
Channel 8	0.005000 V	0.005002 V	0.004977 V	0.005023 V	3.40 e-06 V	0,000002 V	6.67%	Pass
Test @ 0.009V DC								
Channel 1	0.009000 V	0.009005 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000005 V	18.9%	Pass
Channel 2	0.009000 V	0.009002 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000002 V	8.08%	Pass
Channel 3	0.009000 V	0.009004 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000004 V	17.6%	Pass
Channel 4	0.009000 V	0.009003 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000003 V	13.9%	Pass
Channel 5	0.009000 V	0.009003 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000003 V	12.3%	Pass
Channel 6	0.009000 V	0.009001 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000001 V	5.14%	Pass
Channel 7	0.009000 V	0.009004 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000004 V	14.9%	Pass
Channel 8	0.009000 V	0.009002 V	0.008976 V	0.009024 V	3.50 e-06 V	0,000002 V	7.21%	Pass
Test @ -0.009V DC								
Channel 1	-0.009000 V	-0.008998 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000002 V	8.67%	Pass
Channel 2	-0.009000 V	-0.008998 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000002 V	8.95%	Pass
Channel 3	-0.009000 V	-0.008998 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000002 V	9.29%	Pass
Channel 4	-0.009000 V	-0.008999 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000001 V	4.2%	Pass
Channel 5	-0.009000 V	-0.008999 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000001 V	5.63%	Pass
Channel 6	-0.009000 V	-0.008998 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000002 V	7.62%	Pass
Channel 7	-0.009000 V	-0.008999 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000001 V	4.45%	Pass
Channel 8	-0.009000 V	-0.008999 V	-0.009024 V	-0.008976 V	3.50 e-06 V	0,000001 V	4.51%	Pass
Test @ 0.001V_RMS @ 1000Hz								
Channel 1	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	0.444%	Pass
Channel 2	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	1%	Pass
Channel 3	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	0.56%	Pass
Channel 4	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	0.441%	Pass
Channel 5	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	0.559%	Pass
Channel 6	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	1.09%	Pass
Channel 7	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	0.402%	Pass
Channel 8	0.001000 V	0.001000 V	0.000978 V	0.001022 V	8.40 e-06 V	0,000000 V	0.851%	Pass
Test @ 0.007V_RMS @ 20Hz								
Channel 1	0.007000 V	0.007001 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000001 V	3.63%	Pass
Channel 2	0.007000 V	0.007000 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000000 V	0.598%	Pass
Channel 3	0.007000 V	0.007001 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000001 V	2.89%	Pass
Channel 4	0.007000 V	0.007001 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000001 V	3.32%	Pass
Channel 5	0.007000 V	0.007001 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000001 V	2.28%	Pass
Channel 6	0.007000 V	0.007000 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000000 V	1.35%	Pass
Channel 7	0.007000 V	0.007001 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000001 V	3.55%	Pass
Channel 8	0.007000 V	0.007000 V	0.006977 V	0.007023 V	15.00 e-06 V	0,000000 V	0.499%	Pass
Test @ 0.007V_RMS @ 50Hz								
Channel 1	0.007000 V	0.007001 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000001 V	5.61%	Pass
Channel 2	0.007000 V	0.007000 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000000 V	2.02%	Pass
Channel 3	0.007000 V	0.007001 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000001 V	4.77%	Pass
Channel 4	0.007000 V	0.007002 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000002 V	7.48%	Pass
Channel 5	0.007000 V	0.007002 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000002 V	7.52%	Pass
Channel 6	0.007000 V	0.007001 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000001 V	4.27%	Pass
Channel 7	0.007000 V	0.007002 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000002 V	9.96%	Pass
Channel 8	0.007000 V	0.007002 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000002 V	7.54%	Pass
Test @ 0.007V_RMS @ 1000Hz								
Channel 1	0.007000 V	0.007001 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000001 V	2.51%	Pass
Channel 2	0.007000 V	0.007000 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000000 V	1.84%	Pass
Channel 3	0.007000 V	0.007000 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000000 V	1.64%	Pass
Channel 4	0.007000 V	0.007000 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000000 V	2.02%	Pass
Channel 5	0.007000 V	0.007000 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000000 V	1.21%	Pass
Channel 6	0.007000 V	0.006999 V	0.006977 V	0.007023 V	9.50 e-06 V	-0,000001 V	2.55%	Pass
Channel 7	0.007000 V	0.007001 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000001 V	2.31%	Pass
Channel 8	0.007000 V	0.007000 V	0.006977 V	0.007023 V	9.50 e-06 V	0,000000 V	0.684%	Pass
Range: 0.03V #####								
Test @ 0.003V DC								
Channel 1	0.003000 V	0.003004 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000004 V	14.1%	Pass
Channel 2	0.003000 V	0.003002 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000002 V	7.44%	Pass
Channel 3	0.003000 V	0.003003 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000003 V	12.2%	Pass
Channel 4	0.003000 V	0.003002 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000002 V	7.94%	Pass
Channel 5	0.003000 V	0.003002 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000002 V	7.81%	Pass
Channel 6	0.003000 V	0.003002 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000002 V	6.63%	Pass
Channel 7	0.003000 V	0.003002 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000002 V	9.06%	Pass
Channel 8	0.003000 V	0.003001 V	0.002973 V	0.003027 V	3.40 e-06 V	0,000001 V	4.49%	Pass
Test @ 0.015V DC								
Channel 1	0.015000 V	0.015003 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000003 V	10.8%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Channel 2	0.015000 V	0.015001 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000001 V	4.83%	Pass
Channel 3	0.015000 V	0.015002 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000002 V	7.82%	Pass
Channel 4	0.015000 V	0.015002 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000002 V	8.16%	Pass
Channel 5	0.015000 V	0.015002 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000002 V	6.55%	Pass
Channel 6	0.015000 V	0.015003 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000003 V	9.89%	Pass
Channel 7	0.015000 V	0.015002 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000002 V	6.21%	Pass
Channel 8	0.015000 V	0.015000 V	0.014971 V	0.015029 V	3.50 e-06 V	0,000000 V	1.15%	Pass
Test @ 0.027V DC								
Channel 1	0.027000 V	0.027003 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000003 V	8.49%	Pass
Channel 2	0.027000 V	0.027001 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000001 V	4.25%	Pass
Channel 3	0.027000 V	0.027001 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000001 V	4.14%	Pass
Channel 4	0.027000 V	0.027003 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000003 V	8.6%	Pass
Channel 5	0.027000 V	0.027002 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000002 V	5.94%	Pass
Channel 6	0.027000 V	0.027004 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000004 V	11.5%	Pass
Channel 7	0.027000 V	0.027002 V	0.026969 V	0.027031 V	3.60 e-06 V	0,000002 V	4.88%	Pass
Channel 8	0.027000 V	0.026999 V	0.026969 V	0.027031 V	3.60 e-06 V	-0,000001 V	2.55%	Pass
Test @ -0.027V DC								
Channel 1	-0.027000 V	-0.026996 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000004 V	14.1%	Pass
Channel 2	-0.027000 V	-0.026997 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000003 V	9.55%	Pass
Channel 3	-0.027000 V	-0.026994 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000006 V	19.2%	Pass
Channel 4	-0.027000 V	-0.026998 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000002 V	4.99%	Pass
Channel 5	-0.027000 V	-0.026998 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000002 V	7.11%	Pass
Channel 6	-0.027000 V	-0.027000 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000000 V	0.955%	Pass
Channel 7	-0.027000 V	-0.026997 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000003 V	9.66%	Pass
Channel 8	-0.027000 V	-0.026996 V	-0.027031 V	-0.026969 V	3.60 e-06 V	0,000004 V	12.6%	Pass
Test @ 0.021V_RMS @ 20Hz								
Channel 1	0.021000 V	0.020999 V	0.020970 V	0.021030 V	30.00 e-06 V	-0,000001 V	2.87%	Pass Inc
Channel 2	0.021000 V	0.020999 V	0.020970 V	0.021030 V	30.00 e-06 V	-0,000001 V	2.65%	Pass Inc
Channel 3	0.021000 V	0.020998 V	0.020970 V	0.021030 V	30.00 e-06 V	-0,000002 V	6.62%	Pass Inc
Channel 4	0.021000 V	0.021000 V	0.020970 V	0.021030 V	30.00 e-06 V	0,000000 V	1.21%	Pass Inc
Channel 5	0.021000 V	0.021000 V	0.020970 V	0.021030 V	30.00 e-06 V	0,000000 V	0.773%	Pass Inc
Channel 6	0.021000 V	0.021001 V	0.020970 V	0.021030 V	30.00 e-06 V	0,000001 V	3.97%	Pass Inc
Channel 7	0.021000 V	0.020999 V	0.020970 V	0.021030 V	30.00 e-06 V	-0,000001 V	2.54%	Pass Inc
Channel 8	0.021000 V	0.020998 V	0.020970 V	0.021030 V	30.00 e-06 V	-0,000002 V	7.06%	Pass Inc
Test @ 0.021V_RMS @ 50Hz								
Channel 1	0.021000 V	0.021000 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000000 V	0.331%	Pass
Channel 2	0.021000 V	0.021000 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000000 V	1.1%	Pass
Channel 3	0.021000 V	0.020999 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000001 V	2.1%	Pass
Channel 4	0.021000 V	0.021002 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000002 V	6.51%	Pass
Channel 5	0.021000 V	0.021002 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000002 V	5.52%	Pass
Channel 6	0.021000 V	0.021003 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000003 V	10.8%	Pass
Channel 7	0.021000 V	0.021001 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000001 V	4.97%	Pass
Channel 8	0.021000 V	0.021000 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000000 V	0.662%	Pass
Test @ 0.021V_RMS @ 1000Hz								
Channel 1	0.021000 V	0.020998 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000002 V	8.17%	Pass
Channel 2	0.021000 V	0.020997 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000003 V	8.28%	Pass
Channel 3	0.021000 V	0.020996 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000004 V	12.4%	Pass
Channel 4	0.021000 V	0.020999 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000001 V	4.42%	Pass
Channel 5	0.021000 V	0.020998 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000002 V	6.18%	Pass
Channel 6	0.021000 V	0.021000 V	0.020970 V	0.021030 V	12.00 e-06 V	0,000000 V	1.55%	Pass
Channel 7	0.021000 V	0.020998 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000002 V	7.95%	Pass
Channel 8	0.021000 V	0.020996 V	0.020970 V	0.021030 V	12.00 e-06 V	-0,000004 V	12.6%	Pass
Range: 0.1V #####								
Test @ 0.01V DC								
Channel 1	0.010000 V	0.010004 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000004 V	9.76%	Pass
Channel 2	0.010000 V	0.010002 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000002 V	5.63%	Pass
Channel 3	0.010000 V	0.010004 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000004 V	9.13%	Pass
Channel 4	0.010000 V	0.010003 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000003 V	6.67%	Pass
Channel 5	0.010000 V	0.010003 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000003 V	6.51%	Pass
Channel 6	0.010000 V	0.010003 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000003 V	6.75%	Pass
Channel 7	0.010000 V	0.010003 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000003 V	6.11%	Pass
Channel 8	0.010000 V	0.010002 V	0.009958 V	0.010042 V	3.50 e-06 V	0,000002 V	4.6%	Pass
Test @ 0.05V DC								
Channel 1	0.050000 V	0.050005 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000005 V	10.1%	Pass
Channel 2	0.050000 V	0.050003 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000003 V	6.4%	Pass
Channel 3	0.050000 V	0.050003 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000003 V	6.07%	Pass
Channel 4	0.050000 V	0.050003 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000003 V	5.93%	Pass
Channel 5	0.050000 V	0.050004 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000004 V	8.87%	Pass
Channel 6	0.050000 V	0.050005 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000005 V	9.33%	Pass
Channel 7	0.050000 V	0.050002 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000002 V	3.6%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Channel 8	0.050000 V	0.050001 V	0.049950 V	0.050050 V	3.80 e-06 V	0,000001 V	1.13%	Pass
Test @ 0.09V DC								
Channel 1	0.090000 V	0.090005 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000005 V	7.93%	Pass
Channel 2	0.090000 V	0.090002 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000002 V	4.25%	Pass
Channel 3	0.090000 V	0.090001 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000001 V	2.36%	Pass
Channel 4	0.090000 V	0.090001 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000001 V	2.59%	Pass
Channel 5	0.090000 V	0.090005 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000005 V	8.51%	Pass
Channel 6	0.090000 V	0.090005 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000005 V	9.37%	Pass
Channel 7	0.090000 V	0.090000 V	0.089942 V	0.090058 V	4.10 e-06 V	0,000000 V	0.805%	Pass
Channel 8	0.090000 V	0.089998 V	0.089942 V	0.090058 V	4.10 e-06 V	-0,000002 V	3.28%	Pass
Test @ -0.09V DC								
Channel 1	-0.090000 V	-0.089998 V	-0.090058 V	-0.089942 V	4.10 e-06 V	0,000002 V	3.39%	Pass
Channel 2	-0.090000 V	-0.089999 V	-0.090058 V	-0.089942 V	4.10 e-06 V	0,000001 V	2.07%	Pass
Channel 3	-0.090000 V	-0.089994 V	-0.090058 V	-0.089942 V	4.10 e-06 V	0,000006 V	11.1%	Pass
Channel 4	-0.090000 V	-0.089998 V	-0.090058 V	-0.089942 V	4.10 e-06 V	0,000002 V	3.68%	Pass
Channel 5	-0.090000 V	-0.090001 V	-0.090058 V	-0.089942 V	4.10 e-06 V	-0,000001 V	0.92%	Pass
Channel 6	-0.090000 V	-0.090002 V	-0.090058 V	-0.089942 V	4.10 e-06 V	-0,000002 V	3.33%	Pass
Channel 7	-0.090000 V	-0.089995 V	-0.090058 V	-0.089942 V	4.10 e-06 V	0,000005 V	9.37%	Pass
Channel 8	-0.090000 V	-0.089995 V	-0.090058 V	-0.089942 V	4.10 e-06 V	0,000005 V	8.74%	Pass
Test @ 0.07V_RMS @ 20Hz								
Channel 1	0.070000 V	0.070001 V	0.069946 V	0.070054 V	37.00 e-06 V	0,000001 V	2.28%	Pass
Channel 2	0.070000 V	0.070001 V	0.069946 V	0.070054 V	37.00 e-06 V	0,000001 V	1.17%	Pass
Channel 3	0.070000 V	0.069998 V	0.069946 V	0.070054 V	37.00 e-06 V	-0,000002 V	3.33%	Pass
Channel 4	0.070000 V	0.070000 V	0.069946 V	0.070054 V	37.00 e-06 V	0,000000 V	0.617%	Pass
Channel 5	0.070000 V	0.070002 V	0.069946 V	0.070054 V	37.00 e-06 V	0,000002 V	3.46%	Pass
Channel 6	0.070000 V	0.070002 V	0.069946 V	0.070054 V	37.00 e-06 V	0,000002 V	4.44%	Pass
Channel 7	0.070000 V	0.069998 V	0.069946 V	0.070054 V	37.00 e-06 V	-0,000002 V	4.57%	Pass
Channel 8	0.070000 V	0.069997 V	0.069946 V	0.070054 V	37.00 e-06 V	-0,000003 V	5.74%	Pass
Test @ 0.07V_RMS @ 50Hz								
Channel 1	0.070000 V	0.069999 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000001 V	1.54%	Pass
Channel 2	0.070000 V	0.069998 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000002 V	2.84%	Pass
Channel 3	0.070000 V	0.069996 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000004 V	7.28%	Pass
Channel 4	0.070000 V	0.069998 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000002 V	4.26%	Pass
Channel 5	0.070000 V	0.070000 V	0.069946 V	0.070054 V	23.00 e-06 V	0,000000 V	0.432%	Pass
Channel 6	0.070000 V	0.070001 V	0.069946 V	0.070054 V	23.00 e-06 V	0,000001 V	1.6%	Pass
Channel 7	0.070000 V	0.069996 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000004 V	7.65%	Pass
Channel 8	0.070000 V	0.069995 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000005 V	8.7%	Pass
Test @ 0.07V_RMS @ 1000Hz								
Channel 1	0.070000 V	0.069995 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000005 V	9.26%	Pass
Channel 2	0.070000 V	0.069994 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000006 V	10.6%	Pass
Channel 3	0.070000 V	0.069992 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000008 V	15.4%	Pass
Channel 4	0.070000 V	0.069993 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000007 V	12.2%	Pass
Channel 5	0.070000 V	0.069996 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000004 V	7.72%	Pass
Channel 6	0.070000 V	0.069997 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000003 V	6.48%	Pass
Channel 7	0.070000 V	0.069992 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000008 V	15.4%	Pass
Channel 8	0.070000 V	0.069991 V	0.069946 V	0.070054 V	23.00 e-06 V	-0,000009 V	16.9%	Pass
Range: 0.3V #####								
Test @ 0.03V DC								
Channel 1	0.030000 V	0.030004 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000004 V	4.26%	Pass
Channel 2	0.030000 V	0.030002 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000002 V	1.9%	Pass
Channel 3	0.030000 V	0.030002 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000002 V	2.75%	Pass
Channel 4	0.030000 V	0.030001 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000001 V	1.2%	Pass
Channel 5	0.030000 V	0.030003 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000003 V	2.95%	Pass
Channel 6	0.030000 V	0.030003 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000003 V	3.76%	Pass
Channel 7	0.030000 V	0.030001 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000001 V	0.62%	Pass
Channel 8	0.030000 V	0.030000 V	0.029914 V	0.030086 V	3.60 e-06 V	0,000000 V	0.155%	Pass
Test @ 0.15V DC								
Channel 1	0.150000 V	0.150002 V	0.149890 V	0.150110 V	5.30 e-06 V	0,000002 V	1.82%	Pass
Channel 2	0.150000 V	0.149998 V	0.149890 V	0.150110 V	5.30 e-06 V	-0,000002 V	1.82%	Pass
Channel 3	0.150000 V	0.149997 V	0.149890 V	0.150110 V	5.30 e-06 V	-0,000003 V	2.73%	Pass
Channel 4	0.150000 V	0.149999 V	0.149890 V	0.150110 V	5.30 e-06 V	-0,000001 V	0.909%	Pass
Channel 5	0.150000 V	0.150002 V	0.149890 V	0.150110 V	5.30 e-06 V	0,000002 V	1.82%	Pass
Channel 6	0.150000 V	0.150005 V	0.149890 V	0.150110 V	5.30 e-06 V	0,000005 V	4.55%	Pass
Channel 7	0.150000 V	0.149993 V	0.149890 V	0.150110 V	5.30 e-06 V	-0,000007 V	6.67%	Pass
Channel 8	0.150000 V	0.149993 V	0.149890 V	0.150110 V	5.30 e-06 V	-0,000007 V	6.06%	Pass
Test @ 0.27V DC								
Channel 1	0.270000 V	0.270003 V	0.269866 V	0.270134 V	8.20 e-06 V	0,000003 V	1.99%	Pass
Channel 2	0.270000 V	0.269996 V	0.269866 V	0.270134 V	8.20 e-06 V	-0,000004 V	2.99%	Pass
Channel 3	0.270000 V	0.269994 V	0.269866 V	0.270134 V	8.20 e-06 V	-0,000006 V	4.48%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Channel 4	0.270000 V	0.269999 V	0.269866 V	0.270134 V	8.20 e-06 V	-0,000001 V	0.746%	Pass
Channel 5	0.270000 V	0.270005 V	0.269866 V	0.270134 V	8.20 e-06 V	0,000005 V	3.73%	Pass
Channel 6	0.270000 V	0.270009 V	0.269866 V	0.270134 V	8.20 e-06 V	0,000009 V	6.72%	Pass
Channel 7	0.270000 V	0.269988 V	0.269866 V	0.270134 V	8.20 e-06 V	-0,000012 V	8.96%	Pass
Channel 8	0.270000 V	0.269990 V	0.269866 V	0.270134 V	8.20 e-06 V	-0,000010 V	7.46%	Pass
Test @ -0.27V DC								
Channel 1	-0.270000 V	-0.269994 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000006 V	4.48%	Pass
Channel 2	-0.270000 V	-0.269990 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000010 V	7.46%	Pass
Channel 3	-0.270000 V	-0.269985 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000015 V	11.2%	Pass
Channel 4	-0.270000 V	-0.269995 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000005 V	3.73%	Pass
Channel 5	-0.270000 V	-0.269999 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000001 V	0.746%	Pass
Channel 6	-0.270000 V	-0.270003 V	-0.270134 V	-0.269866 V	8.20 e-06 V	-0,000003 V	2.24%	Pass
Channel 7	-0.270000 V	-0.269982 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000018 V	13.4%	Pass
Channel 8	-0.270000 V	-0.269985 V	-0.270134 V	-0.269866 V	8.20 e-06 V	0,000015 V	11.2%	Pass
Test @ 0.21V RMS @ 20Hz								
Channel 1	0.210000 V	0.209999 V	0.209878 V	0.210122 V	90.00 e-06 V	-0,000001 V	0.82%	Pass
Channel 2	0.210000 V	0.209996 V	0.209878 V	0.210122 V	90.00 e-06 V	-0,000004 V	3.28%	Pass
Channel 3	0.210000 V	0.209993 V	0.209878 V	0.210122 V	90.00 e-06 V	-0,000007 V	5.74%	Pass
Channel 4	0.210000 V	0.209999 V	0.209878 V	0.210122 V	90.00 e-06 V	-0,000001 V	0.82%	Pass
Channel 5	0.210000 V	0.210003 V	0.209878 V	0.210122 V	90.00 e-06 V	0,000003 V	2.46%	Pass
Channel 6	0.210000 V	0.210006 V	0.209878 V	0.210122 V	90.00 e-06 V	0,000006 V	4.92%	Pass
Channel 7	0.210000 V	0.209990 V	0.209878 V	0.210122 V	90.00 e-06 V	-0,000010 V	8.2%	Pass
Channel 8	0.210000 V	0.209991 V	0.209878 V	0.210122 V	90.00 e-06 V	-0,000009 V	7.1%	Pass
Test @ 0.21V RMS @ 50Hz								
Channel 1	0.210000 V	0.210004 V	0.209878 V	0.210122 V	66.00 e-06 V	0,000004 V	3.28%	Pass
Channel 2	0.210000 V	0.210000 V	0.209878 V	0.210122 V	66.00 e-06 V	0,000000 V	0%	Pass
Channel 3	0.210000 V	0.209997 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000003 V	2.46%	Pass
Channel 4	0.210000 V	0.210003 V	0.209878 V	0.210122 V	66.00 e-06 V	0,000003 V	2.73%	Pass
Channel 5	0.210000 V	0.210007 V	0.209878 V	0.210122 V	66.00 e-06 V	0,000007 V	6.01%	Pass
Channel 6	0.210000 V	0.210011 V	0.209878 V	0.210122 V	66.00 e-06 V	0,000011 V	9.02%	Pass
Channel 7	0.210000 V	0.209995 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000005 V	4.37%	Pass
Channel 8	0.210000 V	0.209996 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000004 V	3.28%	Pass
Test @ 0.21V RMS @ 1000Hz								
Channel 1	0.210000 V	0.209983 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000017 V	13.9%	Pass
Channel 2	0.210000 V	0.209979 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000021 V	17.2%	Pass
Channel 3	0.210000 V	0.209976 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000024 V	19.7%	Pass
Channel 4	0.210000 V	0.209982 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000018 V	14.8%	Pass
Channel 5	0.210000 V	0.209986 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000014 V	11.5%	Pass
Channel 6	0.210000 V	0.209989 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000011 V	9.02%	Pass
Channel 7	0.210000 V	0.209973 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000027 V	22.1%	Pass
Channel 8	0.210000 V	0.209975 V	0.209878 V	0.210122 V	66.00 e-06 V	-0,000025 V	20.5%	Pass
Range: 1V #####								
Test @ 0.1V DC								
Channel 1	0.100000 V	0.100004 V	0.099760 V	0.100240 V	4.20 e-06 V	0,000004 V	1.67%	Pass
Channel 2	0.100000 V	0.100002 V	0.099760 V	0.100240 V	4.20 e-06 V	0,000002 V	0.694%	Pass
Channel 3	0.100000 V	0.099999 V	0.099760 V	0.100240 V	4.20 e-06 V	-0,000001 V	0.222%	Pass
Channel 4	0.100000 V	0.099999 V	0.099760 V	0.100240 V	4.20 e-06 V	-0,000001 V	0.236%	Pass
Channel 5	0.100000 V	0.100002 V	0.099760 V	0.100240 V	4.20 e-06 V	0,000002 V	0.833%	Pass
Channel 6	0.100000 V	0.100007 V	0.099760 V	0.100240 V	4.20 e-06 V	0,000007 V	2.92%	Pass
Channel 7	0.100000 V	0.099999 V	0.099760 V	0.100240 V	4.20 e-06 V	-0,000001 V	0.542%	Pass
Channel 8	0.100000 V	0.099998 V	0.099760 V	0.100240 V	4.20 e-06 V	-0,000002 V	0.681%	Pass
Test @ -0.1V DC								
Channel 1	-0.100000 V	-0.099996 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000004 V	1.78%	Pass
Channel 2	-0.100000 V	-0.099993 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000007 V	2.74%	Pass
Channel 3	-0.100000 V	-0.099990 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000010 V	3.97%	Pass
Channel 4	-0.100000 V	-0.099998 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000002 V	1.04%	Pass
Channel 5	-0.100000 V	-0.099999 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000001 V	0.347%	Pass
Channel 6	-0.100000 V	-0.099997 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000003 V	1.12%	Pass
Channel 7	-0.100000 V	-0.099992 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000008 V	3.24%	Pass
Channel 8	-0.100000 V	-0.099993 V	-0.100240 V	-0.099760 V	4.20 e-06 V	0,000007 V	3.04%	Pass
Test @ 0.3V DC								
Channel 1	0.300000 V	0.300005 V	0.299720 V	0.300280 V	8.90 e-06 V	0,000005 V	1.79%	Pass
Channel 2	0.300000 V	0.299995 V	0.299720 V	0.300280 V	8.90 e-06 V	-0,000005 V	1.67%	Pass
Channel 3	0.300000 V	0.299991 V	0.299720 V	0.300280 V	8.90 e-06 V	-0,000009 V	3.21%	Pass
Channel 4	0.300000 V	0.299998 V	0.299720 V	0.300280 V	8.90 e-06 V	-0,000002 V	0.833%	Pass
Channel 5	0.300000 V	0.300005 V	0.299720 V	0.300280 V	8.90 e-06 V	0,000005 V	1.79%	Pass
Channel 6	0.300000 V	0.300011 V	0.299720 V	0.300280 V	8.90 e-06 V	0,000011 V	3.93%	Pass
Channel 7	0.300000 V	0.299991 V	0.299720 V	0.300280 V	8.90 e-06 V	-0,000009 V	3.21%	Pass
Channel 8	0.300000 V	0.299992 V	0.299720 V	0.300280 V	8.90 e-06 V	-0,000008 V	2.98%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Test @ 0.5V DC								
Channel 1	0.500000 V	0.500006 V	0.499680 V	0.500320 V	9.80 e-06 V	0,000006 V	1.87%	Pass
Channel 2	0.500000 V	0.499993 V	0.499680 V	0.500320 V	9.80 e-06 V	-0,000007 V	2.08%	Pass
Channel 3	0.500000 V	0.499984 V	0.499680 V	0.500320 V	9.80 e-06 V	-0,000016 V	5%	Pass
Channel 4	0.500000 V	0.499996 V	0.499680 V	0.500320 V	9.80 e-06 V	-0,000004 V	1.35%	Pass
Channel 5	0.500000 V	0.500011 V	0.499680 V	0.500320 V	9.80 e-06 V	0,000011 V	3.44%	Pass
Channel 6	0.500000 V	0.500018 V	0.499680 V	0.500320 V	9.80 e-06 V	0,000018 V	5.52%	Pass
Channel 7	0.500000 V	0.499985 V	0.499680 V	0.500320 V	9.80 e-06 V	-0,000015 V	4.58%	Pass
Channel 8	0.500000 V	0.499987 V	0.499680 V	0.500320 V	9.80 e-06 V	-0,000013 V	3.96%	Pass
Test @ -0.5V DC								
Channel 1	-0.500000 V	-0.500003 V	-0.500320 V	-0.499680 V	9.80 e-06 V	-0,000003 V	0.833%	Pass
Channel 2	-0.500000 V	-0.499991 V	-0.500320 V	-0.499680 V	9.80 e-06 V	0,000009 V	2.92%	Pass
Channel 3	-0.500000 V	-0.499981 V	-0.500320 V	-0.499680 V	9.80 e-06 V	0,000019 V	6.04%	Pass
Channel 4	-0.500000 V	-0.499999 V	-0.500320 V	-0.499680 V	9.80 e-06 V	0,000001 V	0.312%	Pass
Channel 5	-0.500000 V	-0.500013 V	-0.500320 V	-0.499680 V	9.80 e-06 V	-0,000013 V	3.96%	Pass
Channel 6	-0.500000 V	-0.500013 V	-0.500320 V	-0.499680 V	9.80 e-06 V	-0,000013 V	4.17%	Pass
Channel 7	-0.500000 V	-0.499983 V	-0.500320 V	-0.499680 V	9.80 e-06 V	0,000017 V	5.42%	Pass
Channel 8	-0.500000 V	-0.499985 V	-0.500320 V	-0.499680 V	9.80 e-06 V	0,000015 V	4.79%	Pass
Test @ 0.7V DC								
Channel 1	0.700000 V	0.700012 V	0.699640 V	0.700360 V	13.00 e-06 V	0,000012 V	3.24%	Pass
Channel 2	0.700000 V	0.699993 V	0.699640 V	0.700360 V	13.00 e-06 V	-0,000007 V	1.94%	Pass
Channel 3	0.700000 V	0.699979 V	0.699640 V	0.700360 V	13.00 e-06 V	-0,000021 V	5.83%	Pass
Channel 4	0.700000 V	0.699997 V	0.699640 V	0.700360 V	13.00 e-06 V	-0,000003 V	0.741%	Pass
Channel 5	0.700000 V	0.700017 V	0.699640 V	0.700360 V	13.00 e-06 V	0,000017 V	4.72%	Pass
Channel 6	0.700000 V	0.700027 V	0.699640 V	0.700360 V	13.00 e-06 V	0,000027 V	7.41%	Pass
Channel 7	0.700000 V	0.699981 V	0.699640 V	0.700360 V	13.00 e-06 V	-0,000019 V	5.28%	Pass
Channel 8	0.700000 V	0.699982 V	0.699640 V	0.700360 V	13.00 e-06 V	-0,000018 V	5.09%	Pass
Test @ 0.9V DC								
Channel 1	0.900000 V	0.900019 V	0.899600 V	0.900400 V	15.00 e-06 V	0,000019 V	4.67%	Pass
Channel 2	0.900000 V	0.899996 V	0.899600 V	0.900400 V	15.00 e-06 V	-0,000004 V	1%	Pass
Channel 3	0.900000 V	0.899980 V	0.899600 V	0.900400 V	15.00 e-06 V	-0,000020 V	5.08%	Pass
Channel 4	0.900000 V	0.900006 V	0.899600 V	0.900400 V	15.00 e-06 V	0,000006 V	1.5%	Pass
Channel 5	0.900000 V	0.900029 V	0.899600 V	0.900400 V	15.00 e-06 V	0,000029 V	7.25%	Pass
Channel 6	0.900000 V	0.900040 V	0.899600 V	0.900400 V	15.00 e-06 V	0,000040 V	9.92%	Pass
Channel 7	0.900000 V	0.899980 V	0.899600 V	0.900400 V	15.00 e-06 V	-0,000020 V	4.92%	Pass
Channel 8	0.900000 V	0.899981 V	0.899600 V	0.900400 V	15.00 e-06 V	-0,000019 V	4.75%	Pass
Test @ -0.9V DC								
Channel 1	-0.900000 V	-0.900021 V	-0.900400 V	-0.899600 V	15.00 e-06 V	-0,000021 V	5.25%	Pass
Channel 2	-0.900000 V	-0.899998 V	-0.900400 V	-0.899600 V	15.00 e-06 V	0,000002 V	0.417%	Pass
Channel 3	-0.900000 V	-0.899976 V	-0.900400 V	-0.899600 V	15.00 e-06 V	0,000024 V	6.08%	Pass
Channel 4	-0.900000 V	-0.900011 V	-0.900400 V	-0.899600 V	15.00 e-06 V	-0,000011 V	2.83%	Pass
Channel 5	-0.900000 V	-0.900034 V	-0.900400 V	-0.899600 V	15.00 e-06 V	-0,000034 V	8.58%	Pass
Channel 6	-0.900000 V	-0.900039 V	-0.900400 V	-0.899600 V	15.00 e-06 V	-0,000039 V	9.75%	Pass
Channel 7	-0.900000 V	-0.899982 V	-0.900400 V	-0.899600 V	15.00 e-06 V	0,000018 V	4.58%	Pass
Channel 8	-0.900000 V	-0.899986 V	-0.900400 V	-0.899600 V	15.00 e-06 V	0,000014 V	3.42%	Pass
Test @ 0.1V RMS @ 20Hz								
Channel 1	0.100000 V	0.100001 V	0.099760 V	0.100240 V	48.00 e-06 V	0,000001 V	0.278%	Pass
Channel 2	0.100000 V	0.099998 V	0.099760 V	0.100240 V	48.00 e-06 V	-0,000002 V	0.847%	Pass
Channel 3	0.100000 V	0.099996 V	0.099760 V	0.100240 V	48.00 e-06 V	-0,000004 V	1.74%	Pass
Channel 4	0.100000 V	0.099999 V	0.099760 V	0.100240 V	48.00 e-06 V	-0,000001 V	0.278%	Pass
Channel 5	0.100000 V	0.100002 V	0.099760 V	0.100240 V	48.00 e-06 V	0,000002 V	0.833%	Pass
Channel 6	0.100000 V	0.100003 V	0.099760 V	0.100240 V	48.00 e-06 V	0,000003 V	1.25%	Pass
Channel 7	0.100000 V	0.099996 V	0.099760 V	0.100240 V	48.00 e-06 V	-0,000004 V	1.54%	Pass
Channel 8	0.100000 V	0.099997 V	0.099760 V	0.100240 V	48.00 e-06 V	-0,000003 V	1.35%	Pass
Test @ 0.1V RMS @ 50Hz								
Channel 1	0.100000 V	0.100002 V	0.099760 V	0.100240 V	29.00 e-06 V	0,000002 V	0.833%	Pass
Channel 2	0.100000 V	0.099999 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000001 V	0.222%	Pass
Channel 3	0.100000 V	0.099998 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000002 V	0.903%	Pass
Channel 4	0.100000 V	0.100001 V	0.099760 V	0.100240 V	29.00 e-06 V	0,000001 V	0.417%	Pass
Channel 5	0.100000 V	0.100004 V	0.099760 V	0.100240 V	29.00 e-06 V	0,000004 V	1.67%	Pass
Channel 6	0.100000 V	0.100005 V	0.099760 V	0.100240 V	29.00 e-06 V	0,000005 V	2.08%	Pass
Channel 7	0.100000 V	0.099998 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000002 V	0.639%	Pass
Channel 8	0.100000 V	0.099999 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000001 V	0.403%	Pass
Test @ 0.1V RMS @ 1000Hz								
Channel 1	0.100000 V	0.099994 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000006 V	2.69%	Pass
Channel 2	0.100000 V	0.099991 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000009 V	3.85%	Pass
Channel 3	0.100000 V	0.099989 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000011 V	4.63%	Pass
Channel 4	0.100000 V	0.099992 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000008 V	3.21%	Pass
Channel 5	0.100000 V	0.099995 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000005 V	2.17%	Pass
Channel 6	0.100000 V	0.099995 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000005 V	1.89%	Pass
Channel 7	0.100000 V	0.099989 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000011 V	4.65%	Pass
Channel 8	0.100000 V	0.099989 V	0.099760 V	0.100240 V	29.00 e-06 V	-0,000011 V	4.46%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Test @ 0.5V_RMS @ 20Hz								
Channel 1	0.500000 V	0.499991 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000009 V	2.71%	Pass
Channel 2	0.500000 V	0.499978 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000022 V	6.98%	Pass
Channel 3	0.500000 V	0.499966 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000034 V	10.6%	Pass
Channel 4	0.500000 V	0.499984 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000016 V	5.1%	Pass
Channel 5	0.500000 V	0.499997 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000003 V	1.04%	Pass
Channel 6	0.500000 V	0.500002 V	0.499680 V	0.500320 V	250.00 e-06 V	0,000002 V	0.729%	Pass
Channel 7	0.500000 V	0.499972 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000028 V	8.85%	Pass
Channel 8	0.500000 V	0.499974 V	0.499680 V	0.500320 V	250.00 e-06 V	-0,000026 V	8.02%	Pass
Test @ 0.5V_RMS @ 50Hz								
Channel 1	0.500000 V	0.499992 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000008 V	2.5%	Pass
Channel 2	0.500000 V	0.499981 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000019 V	5.94%	Pass
Channel 3	0.500000 V	0.499971 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000029 V	8.96%	Pass
Channel 4	0.500000 V	0.499987 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000013 V	4.06%	Pass
Channel 5	0.500000 V	0.500000 V	0.499680 V	0.500320 V	170.00 e-06 V	0,000000 V	0.104%	Pass
Channel 6	0.500000 V	0.500007 V	0.499680 V	0.500320 V	170.00 e-06 V	0,000007 V	2.08%	Pass
Channel 7	0.500000 V	0.499974 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000026 V	8.13%	Pass
Channel 8	0.500000 V	0.499976 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000024 V	7.6%	Pass
Test @ 0.5V RMS @ 1000Hz								
Channel 1	0.500000 V	0.499960 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000040 V	12.6%	Pass
Channel 2	0.500000 V	0.499946 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000054 V	16.9%	Pass
Channel 3	0.500000 V	0.499935 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000065 V	20.2%	Pass
Channel 4	0.500000 V	0.499951 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000049 V	15.2%	Pass
Channel 5	0.500000 V	0.499964 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000036 V	11.2%	Pass
Channel 6	0.500000 V	0.499968 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000032 V	9.9%	Pass
Channel 7	0.500000 V	0.499937 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000063 V	19.7%	Pass
Channel 8	0.500000 V	0.499941 V	0.499680 V	0.500320 V	170.00 e-06 V	-0,000059 V	18.4%	Pass
Test @ 0.7V RMS @ 20Hz								
Channel 1	0.700000 V	0.700005 V	0.699640 V	0.700360 V	320.00 e-06 V	0,000005 V	1.48%	Pass
Channel 2	0.700000 V	0.699986 V	0.699640 V	0.700360 V	320.00 e-06 V	-0,000014 V	3.8%	Pass
Channel 3	0.700000 V	0.699971 V	0.699640 V	0.700360 V	320.00 e-06 V	-0,000029 V	8.06%	Pass
Channel 4	0.700000 V	0.699993 V	0.699640 V	0.700360 V	320.00 e-06 V	-0,000007 V	1.85%	Pass
Channel 5	0.700000 V	0.700011 V	0.699640 V	0.700360 V	320.00 e-06 V	0,000011 V	3.06%	Pass
Channel 6	0.700000 V	0.700019 V	0.699640 V	0.700360 V	320.00 e-06 V	0,000019 V	5.28%	Pass
Channel 7	0.700000 V	0.699975 V	0.699640 V	0.700360 V	320.00 e-06 V	-0,000025 V	6.94%	Pass
Channel 8	0.700000 V	0.699976 V	0.699640 V	0.700360 V	320.00 e-06 V	-0,000024 V	6.67%	Pass
Test @ 0.7V RMS @ 50Hz								
Channel 1	0.700000 V	0.700007 V	0.699640 V	0.700360 V	210.00 e-06 V	0,000007 V	1.94%	Pass
Channel 2	0.700000 V	0.699990 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000010 V	2.87%	Pass
Channel 3	0.700000 V	0.699977 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000023 V	6.48%	Pass
Channel 4	0.700000 V	0.700002 V	0.699640 V	0.700360 V	210.00 e-06 V	0,000002 V	0.463%	Pass
Channel 5	0.700000 V	0.700018 V	0.699640 V	0.700360 V	210.00 e-06 V	0,000018 V	5%	Pass
Channel 6	0.700000 V	0.700024 V	0.699640 V	0.700360 V	210.00 e-06 V	0,000024 V	6.57%	Pass
Channel 7	0.700000 V	0.699979 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000021 V	5.93%	Pass
Channel 8	0.700000 V	0.699979 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000021 V	5.74%	Pass
Test @ 0.7V RMS @ 1000Hz								
Channel 1	0.700000 V	0.699960 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000040 V	11%	Pass
Channel 2	0.700000 V	0.699943 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000057 V	15.9%	Pass
Channel 3	0.700000 V	0.699929 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000071 V	19.6%	Pass
Channel 4	0.700000 V	0.699951 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000049 V	13.7%	Pass
Channel 5	0.700000 V	0.699967 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000033 V	9.17%	Pass
Channel 6	0.700000 V	0.699972 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000028 V	7.69%	Pass
Channel 7	0.700000 V	0.699930 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000070 V	19.5%	Pass
Channel 8	0.700000 V	0.699931 V	0.699640 V	0.700360 V	210.00 e-06 V	-0,000069 V	19.2%	Pass
Test @ 0.7V RMS @ 10000Hz								
Channel 1	0.700000 V	0.698979 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001021 V	27.4%	Pass
Channel 2	0.700000 V	0.698941 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001059 V	28.5%	Pass
Channel 3	0.700000 V	0.698927 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001073 V	28.8%	Pass
Channel 4	0.700000 V	0.698963 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001037 V	27.9%	Pass
Channel 5	0.700000 V	0.698993 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001007 V	27.1%	Pass
Channel 6	0.700000 V	0.698959 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001041 V	28%	Pass
Channel 7	0.700000 V	0.698968 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001032 V	27.8%	Pass
Channel 8	0.700000 V	0.698962 V	0.696280 V	0.703720 V	160.00 e-06 V	-0,001038 V	27.9%	Pass
Test @ 0.7V RMS @ 20000Hz								
Channel 1	0.700000 V	0.698148 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001852 V	25.7%	Pass
Channel 2	0.700000 V	0.698060 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001940 V	26.9%	Pass
Channel 3	0.700000 V	0.698067 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001933 V	26.8%	Pass
Channel 4	0.700000 V	0.698168 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001832 V	25.4%	Pass
Channel 5	0.700000 V	0.698172 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001828 V	25.3%	Pass
Channel 6	0.700000 V	0.698055 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001945 V	26.9%	Pass
Channel 7	0.700000 V	0.698161 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001839 V	25.5%	Pass
Channel 8	0.700000 V	0.698167 V	0.692780 V	0.707220 V	160.00 e-06 V	-0,001833 V	25.4%	Pass



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Range: 3V #####								
Test @ 0.3V DC								
Channel 1	0.300000 V	0.299987 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000013 V	1.86%	Pass
Channel 2	0.300000 V	0.299977 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000023 V	3.38%	Pass
Channel 3	0.300000 V	0.299985 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000015 V	2.25%	Pass
Channel 4	0.300000 V	0.299983 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000017 V	2.45%	Pass
Channel 5	0.300000 V	0.299988 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000012 V	1.72%	Pass
Channel 6	0.300000 V	0.300007 V	0.299320 V	0.300680 V	8.90 e-06 V	0,000007 V	1.08%	Pass
Channel 7	0.300000 V	0.299974 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000026 V	3.87%	Pass
Channel 8	0.300000 V	0.299982 V	0.299320 V	0.300680 V	8.90 e-06 V	-0,000018 V	2.6%	Pass
Test @ 1.5V DC								
Channel 1	1.500000 V	1.499993 V	1.499080 V	1.500920 V	24.00 e-06 V	-0,000007 V	0.725%	Pass
Channel 2	1.500000 V	1.499963 V	1.499080 V	1.500920 V	24.00 e-06 V	-0,000037 V	3.99%	Pass
Channel 3	1.500000 V	1.499953 V	1.499080 V	1.500920 V	24.00 e-06 V	-0,000047 V	5.07%	Pass
Channel 4	1.500000 V	1.499980 V	1.499080 V	1.500920 V	24.00 e-06 V	-0,000020 V	2.17%	Pass
Channel 5	1.500000 V	1.500020 V	1.499080 V	1.500920 V	24.00 e-06 V	0,000020 V	2.17%	Pass
Channel 6	1.500000 V	1.500050 V	1.499080 V	1.500920 V	24.00 e-06 V	0,000050 V	5.43%	Pass
Channel 7	1.500000 V	1.499940 V	1.499080 V	1.500920 V	24.00 e-06 V	-0,000060 V	6.52%	Pass
Channel 8	1.500000 V	1.499970 V	1.499080 V	1.500920 V	24.00 e-06 V	-0,000030 V	3.26%	Pass
Test @ 2.7V DC								
Channel 1	2.700000 V	2.700020 V	2.698840 V	2.701160 V	41.00 e-06 V	0,000020 V	1.72%	Pass
Channel 2	2.700000 V	2.699950 V	2.698840 V	2.701160 V	41.00 e-06 V	-0,000050 V	4.31%	Pass
Channel 3	2.700000 V	2.699930 V	2.698840 V	2.701160 V	41.00 e-06 V	-0,000070 V	6.03%	Pass
Channel 4	2.700000 V	2.699983 V	2.698840 V	2.701160 V	41.00 e-06 V	-0,000017 V	1.44%	Pass
Channel 5	2.700000 V	2.700050 V	2.698840 V	2.701160 V	41.00 e-06 V	0,000050 V	4.31%	Pass
Channel 6	2.700000 V	2.700090 V	2.698840 V	2.701160 V	41.00 e-06 V	0,000090 V	7.76%	Pass
Channel 7	2.700000 V	2.699917 V	2.698840 V	2.701160 V	41.00 e-06 V	-0,000083 V	7.18%	Pass
Channel 8	2.700000 V	2.699963 V	2.698840 V	2.701160 V	41.00 e-06 V	-0,000037 V	3.16%	Pass
Test @ -2.7V DC								
Channel 1	-2.700000 V	-2.700000 V	-2.701160 V	-2.698840 V	41.00 e-06 V	0,000000 V	3.83e-011%	Pass
Channel 2	-2.700000 V	-2.699950 V	-2.701160 V	-2.698840 V	41.00 e-06 V	0,000050 V	4.31%	Pass
Channel 3	-2.700000 V	-2.699900 V	-2.701160 V	-2.698840 V	41.00 e-06 V	0,000100 V	8.62%	Pass
Channel 4	-2.700000 V	-2.699977 V	-2.701160 V	-2.698840 V	41.00 e-06 V	0,000023 V	2.01%	Pass
Channel 5	-2.700000 V	-2.700047 V	-2.701160 V	-2.698840 V	41.00 e-06 V	-0,000047 V	4.02%	Pass
Channel 6	-2.700000 V	-2.700060 V	-2.701160 V	-2.698840 V	41.00 e-06 V	-0,000060 V	5.17%	Pass
Channel 7	-2.700000 V	-2.699917 V	-2.701160 V	-2.698840 V	41.00 e-06 V	0,000083 V	7.18%	Pass
Channel 8	-2.700000 V	-2.699953 V	-2.701160 V	-2.698840 V	41.00 e-06 V	0,000047 V	4.02%	Pass
Test @ 2.1V_RMS @ 20Hz								
Channel 1	2.100000 V	2.099980 V	2.098960 V	2.101040 V	840.00 e-06 V	-0,000020 V	1.92%	Pass
Channel 2	2.100000 V	2.099943 V	2.098960 V	2.101040 V	840.00 e-06 V	-0,000057 V	5.45%	Pass
Channel 3	2.100000 V	2.099900 V	2.098960 V	2.101040 V	840.00 e-06 V	-0,000100 V	9.62%	Pass
Channel 4	2.100000 V	2.099963 V	2.098960 V	2.101040 V	840.00 e-06 V	-0,000037 V	3.53%	Pass
Channel 5	2.100000 V	2.100007 V	2.098960 V	2.101040 V	840.00 e-06 V	0,000007 V	0.641%	Pass
Channel 6	2.100000 V	2.100027 V	2.098960 V	2.101040 V	840.00 e-06 V	0,000027 V	2.56%	Pass
Channel 7	2.100000 V	2.099910 V	2.098960 V	2.101040 V	840.00 e-06 V	-0,000090 V	8.65%	Pass
Channel 8	2.100000 V	2.099940 V	2.098960 V	2.101040 V	840.00 e-06 V	-0,000060 V	5.77%	Pass
Test @ 2.1V_RMS @ 50Hz								
Channel 1	2.100000 V	2.099993 V	2.098960 V	2.101040 V	470.00 e-06 V	-0,000007 V	0.641%	Pass
Channel 2	2.100000 V	2.099960 V	2.098960 V	2.101040 V	470.00 e-06 V	-0,000040 V	3.85%	Pass
Channel 3	2.100000 V	2.099920 V	2.098960 V	2.101040 V	470.00 e-06 V	-0,000080 V	7.69%	Pass
Channel 4	2.100000 V	2.099980 V	2.098960 V	2.101040 V	470.00 e-06 V	-0,000020 V	1.92%	Pass
Channel 5	2.100000 V	2.100020 V	2.098960 V	2.101040 V	470.00 e-06 V	0,000020 V	1.92%	Pass
Channel 6	2.100000 V	2.100040 V	2.098960 V	2.101040 V	470.00 e-06 V	0,000040 V	3.85%	Pass
Channel 7	2.100000 V	2.099930 V	2.098960 V	2.101040 V	470.00 e-06 V	-0,000070 V	6.73%	Pass
Channel 8	2.100000 V	2.099960 V	2.098960 V	2.101040 V	470.00 e-06 V	-0,000040 V	3.85%	Pass
Test @ 2.1V_RMS @ 1000Hz								
Channel 1	2.100000 V	2.099840 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000160 V	15.4%	Pass
Channel 2	2.100000 V	2.099800 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000200 V	19.2%	Pass
Channel 3	2.100000 V	2.099763 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000237 V	22.8%	Pass
Channel 4	2.100000 V	2.099830 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000170 V	16.3%	Pass
Channel 5	2.100000 V	2.099870 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000130 V	12.5%	Pass
Channel 6	2.100000 V	2.099890 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000110 V	10.6%	Pass
Channel 7	2.100000 V	2.099770 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000230 V	22.1%	Pass
Channel 8	2.100000 V	2.099800 V	2.098960 V	2.101040 V	630.00 e-06 V	-0,000200 V	19.2%	Pass
Range: 10V #####								
Test @ 1V DC								
Channel 1	1.000000 V	1.000017 V	0.997780 V	1.002220 V	17.00 e-06 V	0,000017 V	0.751%	Pass



**DEWETRON GmbH**  
 Parkring 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Channel 2	1.000000 V	0.999963 V	0.997780 V	1.002220 V	17.00 e-06 V	-0,000037 V	1.68%	Pass
Channel 3	1.000000 V	0.999980 V	0.997780 V	1.002220 V	17.00 e-06 V	-0,000020 V	0.916%	Pass
Channel 4	1.000000 V	1.000020 V	0.997780 V	1.002220 V	17.00 e-06 V	0,000020 V	0.901%	Pass
Channel 5	1.000000 V	1.000020 V	0.997780 V	1.002220 V	17.00 e-06 V	0,000020 V	0.901%	Pass
Channel 6	1.000000 V	1.000053 V	0.997780 V	1.002220 V	17.00 e-06 V	0,000053 V	2.4%	Pass
Channel 7	1.000000 V	0.999961 V	0.997780 V	1.002220 V	17.00 e-06 V	-0,000039 V	1.76%	Pass
Channel 8	1.000000 V	1.000002 V	0.997780 V	1.002220 V	17.00 e-06 V	0,000002 V	0.0751%	Pass
Test @ 5V DC								
Channel 1	5.000000 V	4.999963 V	4.996980 V	5.003020 V	110.00 e-06 V	-0,000037 V	1.21%	Pass
Channel 2	5.000000 V	4.999863 V	4.996980 V	5.003020 V	110.00 e-06 V	-0,000137 V	4.53%	Pass
Channel 3	5.000000 V	4.999807 V	4.996980 V	5.003020 V	110.00 e-06 V	-0,000193 V	6.4%	Pass
Channel 4	5.000000 V	5.000000 V	4.996980 V	5.003020 V	110.00 e-06 V	0,000000 V	0%	Pass
Channel 5	5.000000 V	5.000107 V	4.996980 V	5.003020 V	110.00 e-06 V	0,000107 V	3.53%	Pass
Channel 6	5.000000 V	5.000137 V	4.996980 V	5.003020 V	110.00 e-06 V	0,000137 V	4.53%	Pass
Channel 7	5.000000 V	4.999793 V	4.996980 V	5.003020 V	110.00 e-06 V	-0,000207 V	6.84%	Pass
Channel 8	5.000000 V	4.999887 V	4.996980 V	5.003020 V	110.00 e-06 V	-0,000113 V	3.75%	Pass
Test @ 9V DC								
Channel 1	9.000000 V	9.000033 V	8.996180 V	9.003820 V	170.00 e-06 V	0,000033 V	0.873%	Pass
Channel 2	9.000000 V	8.999897 V	8.996180 V	9.003820 V	170.00 e-06 V	-0,000103 V	2.71%	Pass
Channel 3	9.000000 V	8.999723 V	8.996180 V	9.003820 V	170.00 e-06 V	-0,000277 V	7.24%	Pass
Channel 4	9.000000 V	9.000103 V	8.996180 V	9.003820 V	170.00 e-06 V	0,000103 V	2.71%	Pass
Channel 5	9.000000 V	9.000287 V	8.996180 V	9.003820 V	170.00 e-06 V	0,000287 V	7.5%	Pass
Channel 6	9.000000 V	9.000343 V	8.996180 V	9.003820 V	170.00 e-06 V	0,000343 V	8.99%	Pass
Channel 7	9.000000 V	8.999750 V	8.996180 V	9.003820 V	170.00 e-06 V	-0,000250 V	6.54%	Pass
Channel 8	9.000000 V	8.999893 V	8.996180 V	9.003820 V	170.00 e-06 V	-0,000107 V	2.79%	Pass
Test @ -9V DC								
Channel 1	-9.000000 V	-9.000110 V	-9.003820 V	-8.996180 V	170.00 e-06 V	-0,000110 V	2.88%	Pass
Channel 2	-9.000000 V	-8.999987 V	-9.003820 V	-8.996180 V	170.00 e-06 V	0,000013 V	0.349%	Pass
Channel 3	-9.000000 V	-8.999767 V	-9.003820 V	-8.996180 V	170.00 e-06 V	0,000233 V	6.11%	Pass
Channel 4	-9.000000 V	-9.000170 V	-9.003820 V	-8.996180 V	170.00 e-06 V	-0,000170 V	4.45%	Pass
Channel 5	-9.000000 V	-9.000353 V	-9.003820 V	-8.996180 V	170.00 e-06 V	-0,000353 V	9.25%	Pass
Channel 6	-9.000000 V	-9.000347 V	-9.003820 V	-8.996180 V	170.00 e-06 V	-0,000347 V	9.08%	Pass
Channel 7	-9.000000 V	-8.999867 V	-9.003820 V	-8.996180 V	170.00 e-06 V	0,000133 V	3.49%	Pass
Channel 8	-9.000000 V	-8.999937 V	-9.003820 V	-8.996180 V	170.00 e-06 V	0,000063 V	1.66%	Pass
Test @ 7V_RMS @ 20Hz								
Channel 1	7.000000 V	7.000103 V	6.996580 V	7.003420 V	4.10 e-03 V	0,000103 V	3.02%	Pass
Channel 2	7.000000 V	7.000027 V	6.996580 V	7.003420 V	4.10 e-03 V	0,000027 V	0.78%	Pass
Channel 3	7.000000 V	6.999843 V	6.996580 V	7.003420 V	4.10 e-03 V	-0,000157 V	4.58%	Pass
Channel 4	7.000000 V	7.000190 V	6.996580 V	7.003420 V	4.10 e-03 V	0,000190 V	5.56%	Pass
Channel 5	7.000000 V	7.000300 V	6.996580 V	7.003420 V	4.10 e-03 V	0,000300 V	8.77%	Pass
Channel 6	7.000000 V	7.000307 V	6.996580 V	7.003420 V	4.10 e-03 V	0,000307 V	8.97%	Pass
Channel 7	7.000000 V	6.999913 V	6.996580 V	7.003420 V	4.10 e-03 V	-0,000087 V	2.53%	Pass
Channel 8	7.000000 V	6.999970 V	6.996580 V	7.003420 V	4.10 e-03 V	-0,000030 V	0.877%	Pass
Test @ 7V_RMS @ 50Hz								
Channel 1	7.000000 V	7.000177 V	6.996580 V	7.003420 V	2.10 e-03 V	0,000177 V	5.17%	Pass
Channel 2	7.000000 V	7.000083 V	6.996580 V	7.003420 V	2.10 e-03 V	0,000083 V	2.44%	Pass
Channel 3	7.000000 V	6.999913 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000087 V	2.53%	Pass
Channel 4	7.000000 V	7.000237 V	6.996580 V	7.003420 V	2.10 e-03 V	0,000237 V	6.92%	Pass
Channel 5	7.000000 V	7.000337 V	6.996580 V	7.003420 V	2.10 e-03 V	0,000337 V	9.84%	Pass
Channel 6	7.000000 V	7.000343 V	6.996580 V	7.003420 V	2.10 e-03 V	0,000343 V	10%	Pass
Channel 7	7.000000 V	6.999950 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000050 V	1.46%	Pass
Channel 8	7.000000 V	7.000013 V	6.996580 V	7.003420 V	2.10 e-03 V	0,000013 V	0.39%	Pass
Test @ 7V_RMS @ 1000Hz								
Channel 1	7.000000 V	6.999290 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000710 V	20.8%	Pass
Channel 2	7.000000 V	6.999227 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000773 V	22.6%	Pass
Channel 3	7.000000 V	6.999020 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000980 V	28.7%	Pass
Channel 4	7.000000 V	6.999353 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000647 V	18.9%	Pass
Channel 5	7.000000 V	6.999470 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000530 V	15.5%	Pass
Channel 6	7.000000 V	6.999463 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000537 V	15.7%	Pass
Channel 7	7.000000 V	6.999040 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000960 V	28.1%	Pass
Channel 8	7.000000 V	6.999110 V	6.996580 V	7.003420 V	2.10 e-03 V	-0,000890 V	26%	Pass

Non-Accredited functional board tests

SNR Test								
0V @ 10V Range; 100ks/sec								
107.00 dB @ CH1	107.00 dB	107.05 dB	105.00 dB	210.00 dB		0,05 dB	0.047%	Pass (1)
107.00 dB @ CH2	107.00 dB	107.07 dB	105.00 dB	210.00 dB		0,07 dB	0.0632%	Pass (1)
107.00 dB @ CH3	107.00 dB	107.13 dB	105.00 dB	210.00 dB		0,13 dB	0.128%	Pass (1)
107.00 dB @ CH4	107.00 dB	107.14 dB	105.00 dB	210.00 dB		0,14 dB	0.131%	Pass (1)
107.00 dB @ CH5	107.00 dB	107.01 dB	105.00 dB	210.00 dB		0,01 dB	0.00738%	Pass (1)
107.00 dB @ CH6	107.00 dB	107.07 dB	105.00 dB	210.00 dB		0,07 dB	0.0661%	Pass (1)
107.00 dB @ CH7	107.00 dB	107.20 dB	105.00 dB	210.00 dB		0,20 dB	0.194%	Pass (1)
107.00 dB @ CH8	107.00 dB	107.26 dB	105.00 dB	210.00 dB		0,26 dB	0.255%	Pass (1)



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
Short Circuit Input; 10mV Range; 100ks/sec								
72.00 dB @ CH1	72.00 dB	73.14 dB	70.00 dB	200.00 dB		1,14 dB	0.891%	Pass (1)
72.00 dB @ CH2	72.00 dB	73.17 dB	70.00 dB	200.00 dB		1,17 dB	0.911%	Pass (1)
72.00 dB @ CH3	72.00 dB	72.93 dB	70.00 dB	200.00 dB		0,93 dB	0.725%	Pass (1)
72.00 dB @ CH4	72.00 dB	72.97 dB	70.00 dB	200.00 dB		0,97 dB	0.761%	Pass (1)
72.00 dB @ CH5	72.00 dB	73.03 dB	70.00 dB	200.00 dB		1,03 dB	0.802%	Pass (1)
72.00 dB @ CH6	72.00 dB	73.16 dB	70.00 dB	200.00 dB		1,16 dB	0.903%	Pass (1)
72.00 dB @ CH7	72.00 dB	73.22 dB	70.00 dB	200.00 dB		1,22 dB	0.954%	Pass (1)
72.00 dB @ CH8	72.00 dB	73.14 dB	70.00 dB	200.00 dB		1,14 dB	0.889%	Pass (1)
9V @ 10V Range; 100S/sec								
110.00 dB @ CH1	110.00 dB	109.19 dB	105.00 dB	200.00 dB		-0,81 dB	16.1%	Pass (1)
110.00 dB @ CH2	110.00 dB	109.95 dB	105.00 dB	200.00 dB		-0,05 dB	0.903%	Pass (1)
110.00 dB @ CH3	110.00 dB	110.20 dB	105.00 dB	200.00 dB		0,20 dB	0.223%	Pass (1)
110.00 dB @ CH4	110.00 dB	108.70 dB	105.00 dB	200.00 dB		-1,30 dB	26%	Pass (1)
110.00 dB @ CH5	110.00 dB	109.42 dB	105.00 dB	200.00 dB		-0,58 dB	11.6%	Pass (1)
110.00 dB @ CH6	110.00 dB	108.92 dB	105.00 dB	200.00 dB		-1,08 dB	21.7%	Pass (1)
110.00 dB @ CH7	110.00 dB	109.08 dB	105.00 dB	200.00 dB		-0,92 dB	18.3%	Pass (1)
110.00 dB @ CH8	110.00 dB	109.00 dB	105.00 dB	200.00 dB		-1,00 dB	20.1%	Pass (1)
Low pass filter test								
290kHz Filter								
-0.55 dB @ CH1	-0.55 dB	-0.47 dB	-0.70 dB	-0.40 dB		0,08 dB	51.1%	Pass (1)
-0.55 dB @ CH2	-0.55 dB	-0.48 dB	-0.70 dB	-0.40 dB		0,07 dB	47.4%	Pass (1)
-0.55 dB @ CH3	-0.55 dB	-0.48 dB	-0.70 dB	-0.40 dB		0,07 dB	48.9%	Pass (1)
-0.55 dB @ CH4	-0.55 dB	-0.47 dB	-0.70 dB	-0.40 dB		0,08 dB	54.6%	Pass (1)
-0.55 dB @ CH5	-0.55 dB	-0.47 dB	-0.70 dB	-0.40 dB		0,08 dB	53%	Pass (1)
-0.55 dB @ CH6	-0.55 dB	-0.48 dB	-0.70 dB	-0.40 dB		0,07 dB	45.4%	Pass (1)
-0.55 dB @ CH7	-0.55 dB	-0.47 dB	-0.70 dB	-0.40 dB		0,08 dB	54.6%	Pass (1)
-0.55 dB @ CH8	-0.55 dB	-0.47 dB	-0.70 dB	-0.40 dB		0,08 dB	54.1%	Pass (1)
29kHz Filter								
-3.00 dB @ CH1	-3.00 dB	-3.19 dB	-4.00 dB	-2.00 dB		-0,19 dB	18.6%	Pass (1)
-3.00 dB @ CH2	-3.00 dB	-3.13 dB	-4.00 dB	-2.00 dB		-0,13 dB	13%	Pass (1)
-3.00 dB @ CH3	-3.00 dB	-2.98 dB	-4.00 dB	-2.00 dB		0,02 dB	1.84%	Pass (1)
-3.00 dB @ CH4	-3.00 dB	-3.06 dB	-4.00 dB	-2.00 dB		-0,06 dB	5.85%	Pass (1)
-3.00 dB @ CH5	-3.00 dB	-3.08 dB	-4.00 dB	-2.00 dB		-0,08 dB	8.36%	Pass (1)
-3.00 dB @ CH6	-3.00 dB	-3.11 dB	-4.00 dB	-2.00 dB		-0,11 dB	10.5%	Pass (1)
-3.00 dB @ CH7	-3.00 dB	-3.22 dB	-4.00 dB	-2.00 dB		-0,22 dB	22%	Pass (1)
-3.00 dB @ CH8	-3.00 dB	-3.08 dB	-4.00 dB	-2.00 dB		-0,08 dB	7.85%	Pass (1)
2.9kHz Filter								
-3.00 dB @ CH1	-3.00 dB	-3.17 dB	-4.00 dB	-2.00 dB		-0,17 dB	16.8%	Pass (1)
-3.00 dB @ CH2	-3.00 dB	-3.20 dB	-4.00 dB	-2.00 dB		-0,20 dB	20.4%	Pass (1)
-3.00 dB @ CH3	-3.00 dB	-3.16 dB	-4.00 dB	-2.00 dB		-0,16 dB	16.4%	Pass (1)
-3.00 dB @ CH4	-3.00 dB	-3.16 dB	-4.00 dB	-2.00 dB		-0,16 dB	15.5%	Pass (1)
-3.00 dB @ CH5	-3.00 dB	-3.13 dB	-4.00 dB	-2.00 dB		-0,13 dB	13.1%	Pass (1)
-3.00 dB @ CH6	-3.00 dB	-3.10 dB	-4.00 dB	-2.00 dB		-0,10 dB	10.1%	Pass (1)
-3.00 dB @ CH7	-3.00 dB	-3.13 dB	-4.00 dB	-2.00 dB		-0,13 dB	12.8%	Pass (1)
-3.00 dB @ CH8	-3.00 dB	-3.14 dB	-4.00 dB	-2.00 dB		-0,14 dB	14.3%	Pass (1)
0.5Hz High pass filter								
0.5Hz Channel 1								Pass (1)
0.5Hz Channel 2								Pass (1)
0.5Hz Channel 3								Pass (1)
0.5Hz Channel 4								Pass (1)
0.5Hz Channel 5								Pass (1)
0.5Hz Channel 6								Pass (1)
0.5Hz Channel 7								Pass (1)
0.5Hz Channel 8								Pass (1)
3.4Hz High pass filter								
3.4Hz Channel 1								Pass (1)
3.4Hz Channel 2								Pass (1)
3.4Hz Channel 3								Pass (1)
3.4Hz Channel 4								Pass (1)
3.4Hz Channel 5								Pass (1)
3.4Hz Channel 6								Pass (1)
3.4Hz Channel 7								Pass (1)
3.4Hz Channel 8								Pass (1)
10Hz High pass filter								
10Hz Channel 1								Pass (1)
10Hz Channel 2								Pass (1)
10Hz Channel 3								Pass (1)
10Hz Channel 4								Pass (1)
10Hz Channel 5								Pass (1)
10Hz Channel 5								Pass (1)
10Hz Channel 7								Pass (1)
10Hz Channel 8								Pass (1)
Inter Channel Phase Mismatch test at 10kHz signal								
0.000 ° @ CH1	0.000 °	0.000 °	-0.280 °	0.280 °		0,000 °	0%	Pass (1)
0.000 ° @ CH2	0.000 °	-0.042 °	-0.280 °	0.280 °		-0,042 °	15.1%	Pass (1)
0.000 ° @ CH3	0.000 °	0.031 °	-0.280 °	0.280 °		0,031 °	10.9%	Pass (1)
0.000 ° @ CH4	0.000 °	0.023 °	-0.280 °	0.280 °		0,023 °	8.32%	Pass (1)
0.000 ° @ CH5	0.000 °	-0.028 °	-0.280 °	0.280 °		-0,028 °	9.95%	Pass (1)
0.000 ° @ CH6	0.000 °	-0.035 °	-0.280 °	0.280 °		-0,035 °	12.4%	Pass (1)



**DEWETRON GmbH**  
 Parking 4  
 8074 Grambach  
 AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
 Calibration Certificate according to ISO/IEC 17025

AAT2560190
Akkreditierung Austria 0632
03.04.2025

**11. Testergebnisse / Test results**

Test Description	True Value	Test Result	Lower limit	Upper limit	Exp Uncert	Error	% of Tol	Status
0.000 ° @ CH7	0.000 °	0.039 °	-0.280 °	0.280 °		0,039 °	14%	Pass (1)
0.000 ° @ CH8	0.000 °	0.025 °	-0.280 °	0.280 °		0,025 °	8.82%	Pass (1)
CMRR test at 50Hz								
80.0 dB @ CH1	80.0 dB	104.6 dB	80.0 dB	200.0 dB		24,6 dB	20.5%	Pass (1)
80.0 dB @ CH2	80.0 dB	97.4 dB	80.0 dB	200.0 dB		17,4 dB	14.5%	Pass (1)
80.0 dB @ CH3	80.0 dB	100.4 dB	80.0 dB	200.0 dB		20,4 dB	17%	Pass (1)
80.0 dB @ CH4	80.0 dB	98.8 dB	80.0 dB	200.0 dB		18,8 dB	15.7%	Pass (1)
80.0 dB @ CH5	80.0 dB	99.1 dB	80.0 dB	200.0 dB		19,1 dB	15.9%	Pass (1)
80.0 dB @ CH6	80.0 dB	97.8 dB	80.0 dB	200.0 dB		17,8 dB	14.8%	Pass (1)
80.0 dB @ CH7	80.0 dB	103.6 dB	80.0 dB	200.0 dB		23,6 dB	19.7%	Pass (1)
80.0 dB @ CH8	80.0 dB	105.2 dB	80.0 dB	200.0 dB		25,2 dB	21%	Pass (1)
CMRR test at 1kHz								
70.0 dB @ CH1	70.0 dB	87.3 dB	70.0 dB	200.0 dB		17,3 dB	13.3%	Pass (1)
70.0 dB @ CH2	70.0 dB	87.0 dB	70.0 dB	200.0 dB		17,0 dB	13.1%	Pass (1)
70.0 dB @ CH3	70.0 dB	87.5 dB	70.0 dB	200.0 dB		17,5 dB	13.5%	Pass (1)
70.0 dB @ CH4	70.0 dB	88.1 dB	70.0 dB	200.0 dB		18,1 dB	13.9%	Pass (1)
70.0 dB @ CH5	70.0 dB	86.6 dB	70.0 dB	200.0 dB		16,6 dB	12.8%	Pass (1)
70.0 dB @ CH6	70.0 dB	86.8 dB	70.0 dB	200.0 dB		16,8 dB	13%	Pass (1)
70.0 dB @ CH7	70.0 dB	87.3 dB	70.0 dB	200.0 dB		17,3 dB	13.3%	Pass (1)
70.0 dB @ CH8	70.0 dB	87.3 dB	70.0 dB	200.0 dB		17,3 dB	13.3%	Pass (1)
Bridge-Completion and Shunt Checks								
350R Quarter Bridge Offset Check								
Channel 1 350R Quarter Bridge Offset								Pass (1)
Channel 2 350R Quarter Bridge Offset								Pass (1)
Channel 3 350R Quarter Bridge Offset								Pass (1)
Channel 4 350R Quarter Bridge Offset								Pass (1)
Channel 5 350R Quarter Bridge Offset								Pass (1)
Channel 6 350R Quarter Bridge Offset								Pass (1)
Channel 7 350R Quarter Bridge Offset								Pass (1)
Channel 8 350R Quarter Bridge Offset								Pass (1)
120R Quarter Bridge Completion								
Channel 1 120R Quarter Bridge Offset								Pass (1)
Channel 2 120R Quarter Bridge Offset								Pass (1)
Channel 3 120R Quarter Bridge Offset								Pass (1)
Channel 4 120R Quarter Bridge Offset								Pass (1)
Channel 5 120R Quarter Bridge Offset								Pass (1)
Channel 6 120R Quarter Bridge Offset								Pass (1)
Channel 7 120R Quarter Bridge Offset								Pass (1)
Channel 8 120R Quarter Bridge Offset								Pass (1)
350R Quarter Br. & 50k Shunt Resistor								
Channel 1 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 2 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 3 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 4 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 5 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 6 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 7 350R Quarter Bridge & 50k Shunt Check								Pass (1)
Channel 8 350R Quarter Bridge & 50k Shunt Check								Pass (1)
350R Quarter Br. & 100k Shunt Resistor								
Channel 1 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 2 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 3 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 4 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 5 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 6 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 7 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Channel 8 350R Quarter Bridge & 100k Shunt Check								Pass (1)
Hardware Check (Selftest)								Pass (1)
Hardware Check (Excitation Test)								Pass (1)
40 °C @ BoardTemp	40. °C	42 °C	25 °C	55 °C		2,00 °C	11.7%	Pass (1)

Ende des Kalibrierscheines / End of Calibration Certificate



**DEWETRON GmbH**  
Parking 4  
8074 Grambach  
AUSTRIA

Kalibrierschein nach ISO/IEC 17025  
*Calibration Certificate according to ISO/IEC 17025*

AAT2560190
Akkreditierung Austria 0632
03.04.2025

